



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Name: MAZURE - Spa

Street Location: 11 BLAIR RD

Zoning District: R-2A

Property Acreage: 2.00

Tax ID: 101.04-1-24

RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit

Date: November 2, 2016

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on November 1, 2016.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The plan should be revised to depict the proposed deck and spa location with respect to all property lines. In addition, a zoning conformance table should be added to the plan.
- Submission of gross land coverage backup information.
- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access and silt fence. Provide details.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP
Director of Planning