



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Name: ADAMSKY - Solar Panels

Street Location: 11 COBBLERS LN

Zoning District: R-2A Property Acreage: 1.19 Tax ID: 101.03-1-13

RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board  
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals  
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit

Date: July 18, 2018

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on July 17, 2018.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The Building Department shall determine whether a permit is required for the on-going deck repair work at the rear of the house.
- The existing solar panel installation does not appear to match the previously approved plans. The Building Department shall determine whether amended permits are required.
- Since the previously approved solar installation and the proposed new solar installation are over 10kW, the Applicant will need to:
  - provide a plan for the operation and maintenance of the large-scale solar installation, including, but not limited to, measures for maintaining safe access to the installation, stormwater controls, landscaping, and adequate security as well as general procedures for operational maintenance of the installation.
  - provide a copy of the project summary, electrical schematic, and site plan to the Fire Chief. Upon request, the owner or operator shall cooperate with emergency service providers in developing an emergency response plan. All means of shutting down the solar installation shall be clearly marked. The owner or operator shall identify a responsible person for public inquiry throughout the life of the installation.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP  
Director of Planning