



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Name: DAVAR - PLAN AMENDMENT
Street Location: 11 HISSARLIK WAY
Zoning District: R-2A Property Acreage: 2.00 Tax ID: 102.01-2-44
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit
Date: October 10, 2017

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on October 3, 2017.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

-) The plan shall clarify how the embankment will be stabilized, if rock is not encountered, to the satisfaction of the Town Engineer.
-) The drawing scale should be noted on the plan to the satisfaction of the Town Engineer.
-) The plan shall illustrate and quantify the limits of disturbance to the satisfaction of the Town Engineer. The plan shall note that disturbance limits shall be staked in the field prior to construction.
-) All trees 8 inches dbh or greater located within or 10 feet beyond the proposed limit of disturbance shall be shown on the plan to the satisfaction of the Town Engineer. Indicate trees to be removed and/or protected.
-) Include erosion control measures on the plan, including, but not limited to, temporary construction access, tree protection, erosion control blankets, construction sequence, etc. to the satisfaction of the Town Engineer. Provide details.
-) It appears that disturbances are proposed within the locally-regulated 100 foot wetland buffer. A local Wetland Permit may be required. The applicant shall illustrate the local wetland boundary and regulated 100 foot buffer on the plan for verification by the Town Wetland Consultant. Notify the Town Engineer once the wetland boundary has been established in the field.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.