



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Name: TRUDELL - Deck

Street Location: 13 N LAKE RD

Zoning District: R-1A Property Acreage: 2.21 Tax ID: 101.02-3-25

RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals
☒ Submit to Building Department ☒ Requires Admin Wetlands Permit

Date: April 4, 2018

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on April 3, 2018.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- It appears that disturbances are proposed within the locally-regulated 100 foot wetland buffer. A local Wetland Permit may be required. The applicant shall illustrate the local wetland boundary and regulated 100 foot buffer on the plan for verification by the Town Wetland Consultant. Notify the Town Engineer once the wetland boundary has been established in the field.
- It appears that a significant amount of the Town-regulated wetland buffer is maintained lawn. It is suggested that the area to the south of the footbridge be mitigated and retuned to a naturalized condition.
- Submission of gross land coverage backup information.
- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Provide construction details for all proposed improvements, including, but not limited to, driveway, drainage, curbing, walkways, erosion controls, etc.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, tree protection, erosion control blankets, construction sequence, etc. Provide details.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.