



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Name: MONASEBIAN - Exterior Modification

Street Location: 188 BYRAM LAKE RD

Zoning District: R-2A Property Acreage: 1.84 Tax ID: 101.02-1-25

RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board  
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals  
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit

Date: April 4, 2018

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on April 3, 2018.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The existing sewer connection shall be sleeved for protection from vehicle loading in the location of the proposed driveway. Provide a detail.
- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Show all required minimum yard setbacks on the plan.
- Provide existing and proposed topography for the area of work.
- All trees 8 inches dbh or greater located within or 10 feet beyond the proposed limit of disturbance shall be shown on the plan. Indicate trees to be removed and/or protected.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, tree protection, erosion control blankets, construction sequence, etc. Provide details.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.