



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Name: BILOTTI - Deck
Street Location: 25 GREEN VALLEY RD
Zoning District: R-2A Property Acreage: 2.09 Tax ID: 108.02-2-46
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals
☒ Submit to Building Department ☒ Requires Admin Wetlands Permit
Date: September 13, 2016

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on September 13, 2016.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, tree protection, erosion control blankets, construction sequence, etc. Provide details.
- It appears that disturbances are proposed within the locally-regulated 100 foot wetland buffer and the NYSDEC 100 foot wetland adjacent area. A local Wetland Permit and/or NYSDEC Freshwater Wetland Permit may be required. The applicant shall illustrate the local and/or NYSDEC wetland boundary and regulated 100 foot buffer on the plan for verification by the Town Wetland Consultant and/or NYSDEC validation. Notify the Town Engineer once the wetland boundary has been established in the field.
- The plan proposes disturbances and improvements within the regulated 100 foot wetland buffer. The applicant shall provide mitigation of the buffer disturbance at a ratio of 2:1. Provide a wetland mitigation plan for review by the Town Wetland Consultant.
- It appears that disturbance is proposed within a 100-year FEMA Floodplain Zone A. The limits of the zone shall be shown on the plan. A Floodplain Development Permit will be required in accordance with Chapter 109 - Flood Damage Prevention of the Town Code.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP
Director of Planning