

## TOWN OF NORTH CASTLE

## WESTCHESTER COUNTY 17 Bedford Road Armonk, New York 10504-1898

RESIDENTIAL PROJECT REVIEW COMMITTEE Adam R. Kaufman AICP, Chair Telephone: (914) 273-8625 Fax: (914) 273-3554 www.northcastleny.com

## RPRC DETERMINATION LETTER

| Project Name:  | 55 Hammond Ridge Road Deck - PORCH ADDITION |  |                                       |                      |
|--|---|--|---------------------------------------|----------------------|
| Street Location:   | 55 HAMMOND RIDGE RD                         |  |                                       |                      |
| Zoning District:   | R-2A Property Acrea                         |  | ge: 8.29                              | Tax ID: 101.01-1-1.1 |
| RPRC DECISION:   | ☐ Requires Planning Board Review            |  | ☐ Requires Architectural Review Board |                      |
|  | ☐ Requires Conservation Board               |  | ☐ Requires Zoning Board of Appeals    |                      |
|  | ■ Submit to Building Department             |  | ☐ Requires Admin Wetlands Permit      |                      |
| Date:  | September 5, 2017                           |  |                                       |                      |
| The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on August 22, 2017.  The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.  |   |  |                                       |                      |
| However, the following issues will need to be addressed prior to the issuance of a building permit:  |   |  |                                       |                      |
| <ul> <li>The site plan shall be revised to depict the Applicant's entire property and adjacent properties and streets.</li> <li>The site plan shall be revised to depict the location of the existing septic system and well.</li> <li>The site plan shall be revised to depict a Zoning Conformance Table depicting the plan's compliance with the minimum requirements of the Zoning District.</li> <li>The site contains Town-regulated wetlands. The site plan should be revised to depict the location of the wetland and the 100-foot buffer.</li> <li>The proposed roof leaders shall be connected to the existing drainage system. The connection should be shown on the site plan.</li> </ul> |   |  |                                       |                      |

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP Director of Planning