

TOWN OF NORTH CASTLE

WESTCHESTER COUNTY 17 Bedford Road Armonk, New York 10504-1898

RESIDENTIAL PROJECT REVIEW COMMITTEE Adam R. Kaufman AICP, Chair Telephone: (914) 273-8625 Fax: (914) 273-3554 www.northcastleny.com

RPRC DETERMINATION LETTER

Project Name:	BURBA - Pool				
Street Location:	11 HOLLOW RIDGE RD				
Zoning District:	R-2A	Property Acrea	ge: 4.3	Tax ID: 100.02-1-48	
RPRC DECISION:	☐ Requires Planning Board Review		☐ Requires Architectural Review Board		
	☐ Requires Conservation Board ■ Submit to Building Department		☐ Requires Zoning Board of Appeals		
			■ Requires Admin Wetlands Permit		
Date:	July 22, 2015				

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on July 21, 2015.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The applicant shall submit a proposed pool fence and gate detail.
- The gross land coverage information on the Zoning Conformance Chart shall be revised to indicate 20,803.7 square feet as the maximum permitted amount of gross land coverage.
- Show the connection between the pool and pool equipment.
- Demonstrate that the existing infiltration has adequate capacity to mitigate the pool drawdown. Additional chambers may be required.
- Provide a terrace detail.
- It appears that disturbances are proposed within the locally-regulated 100 foot wetland buffer. A local Wetland Permit may be required. The applicant shall illustrate the local wetland boundary on the plan for verification by the Town Wetland Consultant. Notify the Town Engineer once the wetland boundary has been established in the field.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.