



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Name: DEANGELIS - Addition  
Street Location: 101 BYRAM RIDGE RD  
Zoning District: R-1A Property Acreage: 1 Tax ID: 101.01-1-12  
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board  
☐ Requires Conservation Board ☒ Requires Zoning Board of Appeals  
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit  
Date: September 30, 2014

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on September 30, 2014.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The applicant will require a side yard variance from the Zoning Board of Appeals.
- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Show all required minimum yard setbacks on the plan.
- The Building Department shall determine the need to refer the application to the Westchester County Department of Health (WCHD) for the bedroom count and/or additional floor area.
- The applicant shall perform deep and percolation soil testing to be witnessed by the Town Engineer. The test locations and results shall be shown on the plan. Contact this office to schedule the testing.
- Provide stormwater mitigation and design calculations for the runoff generated by the 25-year storm for the net increase in impervious surface. Provide details of the stormwater mitigation system.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, tree protection, erosion control blankets, construction sequence, etc. Provide details.
- Provide a construction detail for the proposed pavement.

- Provide existing and proposed grading for the driveway area.
- Need GLC and GFA backup information
- Proposed plans should be sent to Health Department for bedroom count review. Proposed Bonus room may be considered bedroom.
- The site plan should be revised to depict the existing accessory structures on the property (e.g., shed, chicken coop, etc.). The gross land coverage worksheet should be revised, if necessary.

At this time you may coordinate directly with the North Castle Building Department. **DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.**

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP  
Director of Planning