



TOWN OF NORTH CASTLE

WESTCHESTER COUNTY
17 Bedford Road
Armonk, New York 10504-1898

RESIDENTIAL PROJECT
REVIEW COMMITTEE
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625
Fax: (914) 273-3554
www.northcastleny.com

RPRC DETERMINATION LETTER

Project Name: GOLDMAN - Pool
Street Location: 6 THORNEWOOD RD
Zoning District: R-1.5A Property Acreage: 1.51 Tax ID: 102.01-1-55
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit
Date: November 14, 2014

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on November 12, 2014.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Include the driveway removal in the limits of disturbance and clarify how this area will be restored.
- The applicant shall perform deep and percolation soil testing to be witnessed by the Town Engineer. The test locations and results shall be shown on the plan. Contact Town Engineer to schedule the testing.
- Provide stormwater mitigation design calculations for the runoff generated by the 25-year storm for the net increase in impervious surface or a 6 inch pool drawdown volume; whichever is greater. Provide details of the stormwater mitigation system.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, tree protection, erosion control blankets, construction sequence, etc. Provide details.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.