



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Name: MILLER - Fence  
Street Location: 15 MIDDLE PATENT RD  
Zoning District: R-2A Property Acreage: 20.63 Tax ID: 95.03-1-44  
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board  
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals  
☒ Submit to Building Department ☒ Requires Admin Wetlands Permit  
Date: August 12, 2015

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on August 11, 2015.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The site plan shall contain a proposed planting schedule that includes the scientific name of the plant, common name, quantity and proposed size of the proposed material.
- The ravine patio depicts a wall larger than 4 feet in height. All walls over four feet in height are required to be designed by an engineer. It is recommended that the plan (and detail) be revised to depict a wall less than four feet in height. Clarify if electrical service will be connected to the proposed gate. If so, illustrate the route on the plan and provide a utility trench detail.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, tree protection, erosion control blankets, construction sequence, etc. Provide details.
- It appears that disturbances are proposed within the locally-regulated 100 foot wetland buffer. A local Wetland Permit may be required. The applicant shall illustrate the local wetland boundary and regulated 100 foot buffer on the plan for verification by the Town Wetland Consultant.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.