



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Name: O'CONNOR - Pool  
Street Location: 54 CREEMER RD  
Zoning District: R-2A Property Acreage: 7.76 Tax ID: 109.01-1-46  
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board  
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals  
☒ Submit to Building Department ☒ Requires Admin Wetlands Permit  
Date: November 3, 2015

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on November 3, 2015.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The applicant shall perform deep and percolation soil testing to be witnessed by the Town Engineer. The test locations and results shall be shown on the plan. Contact the Town Engineer to schedule the testing.
- Provide stormwater mitigation design calculations for the runoff generated by the 25-year storm for the net increase in impervious surface or a 6 inch pool drawdown volume; whichever is greater. Provide details of the stormwater mitigation system.
- Show the connection between the pool equipment and drawdown mitigation practice.
- Clarify the invert of the infiltration system, it appears the northern end will require additional cover.
- It appears that disturbances are proposed within the locally-regulated 100 foot wetland buffer. A local Administrative Wetland Permit shall be required. The applicant shall illustrate the local wetland boundary and regulated 100 foot buffer on the plan for verification by the Town Wetland Consultant. Notify the Town Engineer once the wetland boundary has been established in the field.
- The plan proposes disturbances and improvements within the regulated 100 foot wetland buffer. The applicant shall provide mitigation of the buffer disturbance at a ratio of 2:1. Provide a wetland mitigation plan for review by the Town Wetland Consultant.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.