



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Name: SURACE - Addition  
Street Location: 8 LANDER PL  
Zoning District: R-5 Property Acreage: 0.49 Tax ID: 108.01-3-52  
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board  
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals  
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit  
Date: February 20, 2015

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on February 20, 2015.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- Site plan should be revised to depict location of proposed deck.
- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- Provide a copy of the Westchester County Department of Health (WCHD) approval for the proposed modifications to the on-site wastewater treatment system.
- Show existing septic and septic improvements on the site plan.
- Drywells should be installed at a minimum of 10 feet from the property line.
- Show the pipe connection to the drywell.
- Include erosion control measures on the plan, including, but not limited to, temporary construction access, silt fence, inlet protection, tree protection, erosion control blankets, construction sequence, etc. Provide details.
- Show the location of the existing septic primary and expansion areas on the plan. The plan shall show this area to be cordoned off during construction.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.