

TOWN OF NORTH CASTLE

WESTCHESTER COUNTY 17 Bedford Road Armonk, New York 10504-1898

RESIDENTIAL PROJECT REVIEW COMMITTEE Adam R. Kaufman AICP. Chair Telephone: (914) 273-8625 Fax: (914) 273-3554 www.northcastleny.com

RPRC DETERMINATION LETTER

Date:	November 6, 2019	
	■ Submit to Building Department	☐ Requires Admin Wetlands Permit
	☐ Requires Conservation Board	☐ Requires Zoning Board of Appeals
RPRC DECISION:	☐ Requires Planning Board Review	☐ Requires Architectural Review Board
	Zoning District: R-2A Property Acreage: 2.94 Tax ID: 94.04-2-21	
Street Location:	18 HEMLOCK HOLLOW RD	
Project Name:	SAMPATH - Solar Panels	

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on November 6, 2019.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

Since the proposed installation is over 10kW in size, the following additional requirements must be met:

- Large-scale solar installations shall provide a plan for the operation and maintenance of the large-scale solar installation, including, but not limited to, measures for maintaining safe access to the installation, stormwater controls, landscaping, and adequate security as well as general procedures for operational maintenance of the installation.
- Large-scale solar installations shall provide a copy of the project summary, electrical schematic, and site plan to the Fire Chief. Upon request, the owner or operator shall cooperate with emergency service providers in developing an emergency response plan. All means of shutting down the solar installation shall be clearly marked. The owner or operator shall identify a responsible person for public inquiry throughout the life of the installation.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.