



# TOWN OF NORTH CASTLE

WESTCHESTER COUNTY  
17 Bedford Road  
Armonk, New York 10504-1898

RESIDENTIAL PROJECT  
REVIEW COMMITTEE  
Adam R. Kaufman AICP, Chair

Telephone: (914) 273-8625  
Fax: (914) 273-3554  
www.northcastleny.com

## RPRC DETERMINATION LETTER

Project Name: TAFFET - Pool  
Street Location: 2 HARDSCRABBLE CIR  
Zoning District: R-1A Property Acreage: 1.00 Tax ID: 101.02-3-40  
RPRC DECISION: ☐ Requires Planning Board Review ☐ Requires Architectural Review Board  
☐ Requires Conservation Board ☐ Requires Zoning Board of Appeals  
☒ Submit to Building Department ☐ Requires Admin Wetlands Permit  
Date: February 25, 2019

---

The above referenced application was reviewed by the Residential Project Review Committee (RPRC) on February 19, 2019.

The Committee determined that Planning Board and Architectural Review Board approval of the proposed project is NOT REQUIRED.

However, the following issues will need to be addressed prior to the issuance of a building permit:

- The Applicant shall submit gross land coverage backup information for review.
- The site plan shall be revised to dimension the southwestern corner of the pool to the rear property line.
- The site plan shall be revised to eliminate the cabana since the cabana is not proposed to be constructed at this time.
- The gross land coverage calculations worksheet (and backup data) should be revised to eliminate the proposed cabana since the cabana is not proposed to be constructed at this time.
- The plan shall include proposed grading.
- The plan shall illustrate and quantify the limits of disturbance. The plan shall note that disturbance limits shall be staked in the field prior to construction.
- The applicant shall perform deep and percolation soil testing to be witnessed by the Town Engineer. The test locations and results shall be shown on the plan. Contact the Town Engineer to schedule the testing.

- Provide stormwater mitigation design calculations for the runoff generated by the 25-year storm for the net increase in impervious surface or a 6 inch pool drawdown volume; whichever is greater. Provide details of the stormwater mitigation system.
- Provide rims, inverts, size and material for all drainage facilities. Provide details.
- Show the connection between the pool equipment and drawdown mitigation practice.
- All trees 8 inches dbh or greater located within or 10 feet beyond the proposed limit of disturbance shall be shown on the plan. Indicate trees to be removed and/or protected.

At this time you may coordinate directly with the North Castle Building Department. DO NOT START CONSTRUCTION WITHOUT A VALID BUILDING DEPARTMENT PERMIT.

If you would like to further discuss this matter, please do not hesitate to contact the Building Department.

Adam R. Kaufman, AICP  
Director of Planning